



شرکت پیشگامان انرژی نورا تک

مدیر محترم پروژه

موضوع: احداث نیروگاه خورشیدی ۲۰ مگاواتی زارچ یزد

اصلاح لیست مدارک الکتریکی ساختمان

با سلام و احترام،

با توجه به بررسی انجام شده بر مدارک الکتریکی ساختمان در پروژه ۲۰ مگاوات زارچ، مشخص گردید مدرک Indoor and Outdoor Electrical Plan & Details for Building با شماره 410-DE-EL-DRW-0048 به صورت کلی تهیه گردیده و به دلیل عدم ارائه جزئیات لازم، امکان انجام بررسی دقیق فنی بر روی آن فراهم نمی باشد.

لذا خواهشمند است مدرک مذکور از لیست مدارک (MDL) پروژه حذف شده و به جای آن، مدارک تفصیلی مرتبط مطابق با لیست پیشنهادی ذیل در MDL پروژه درج و جهت بررسی ارائه گردد.

LIGHTING & SOCKET LAYOUT (FOR CONTROL, MV SWITCHGEAR & GAURD BUILDING)
NETWORK & VOIP SYSTEM LAYOUT (FOR CONTROL, MV SWITCHGEAR & GAURD BUILDING)
FIRE ALARM SYSTEM & BLOCK DIAGRAM (FOR CONTROL, MV SWITCHGEAR & GAURD BUILDING)
CABLING & CABLE ROUTE LAYOUT (FOR CONTROL, MV SWITCHGEAR & GAURD BUILDING)
ELECTRICAL EQUIPMENT LAYOUT (FOR CONTROL, MV SWITCHGEAR & GAURD BUILDING)
EARTHING SYSTEM LAYOUT (FOR CONTROL, MV SWITCHGEAR & GAURD BUILDING)
CCTV SYSTEM LAYOUT (FOR CONTROL, MV SWITCHGEAR & GAURD BUILDING)
Building electrical equipment MTO (FOR CONTROL, MV SWITCHGEAR & GAURD BUILDING)



با تشکر
حمیدرضا دبیری
مدیر پروژه